

# TOWN OF WASHINGTON

BRYAN MEMORIAL TOWN HALL  
POST OFFICE BOX 383  
WASHINGTON DEPOT, CONNECTICUT 06794

## Application for Approval for Swimming Pool Location/Installation

NAME OF OWNER \_\_\_\_\_

PROPERTY ADDRESS \_\_\_\_\_

SUBDIVISION AND LOT# \_\_\_\_\_

TYPE OF POOL (ABOVE/BELOW GROUND) \_\_\_\_\_ FILTER TYPE \_\_\_\_\_

Pool installer \_\_\_\_\_

Minimum separating distance from pool to septic system and/or well \_\_\_\_\_  
(Requirement is 10' from above ground to septic, 25' from below ground to septic or well)

Backwash wastewater discharge location \_\_\_\_\_  
see back

Draining wastewater discharge location \_\_\_\_\_  
see back

Cleaning wastewater discharge location \_\_\_\_\_  
see back

Note: Backwash wastewater may only be discharged to a sanitary sewer or subsurface leaching system. Draining wastewater may be discharged to sanitary sewer surface water body or subsurface leaching system. Cleaning wastewater may only be discharged to sanitary sewer.

\_\_\_\_\_  
Date

\_\_\_\_\_  
Applicant Signature

-----  
Sketch of Pool Location, Septic System and any wastewater discharge system

-----  
Health Dept. Use

POOL LOCATION/INSTALLATION APPROVED: \_\_\_\_\_

BY \_\_\_\_\_ DATE \_\_\_\_\_ FEE RECEIVED \_\_\_\_\_

COMMENTS: \_\_\_\_\_

# GUIDELINES FOR THE DISCHARGE OF SWIMMING POOL WASTEWATERS

Revisions 5/21/90

These guidelines were developed by the Connecticut Department of Environmental Protection for the handling of wastewater discharges from swimming pools, and are intended to protect the waters of the State, including sanitary sewer systems, from adverse impacts due to these discharges.

## GENERAL REQUIREMENTS:

The various types of Swimming Pool Wastewater may only discharge to the DISCHARGE LOCATIONS with are ALLOWED as indicated in the following chart. If a discharge is allowed to a certain location, the DISCHARGE CONDITIONS listed in this chart must be met.

DISCHARGE LOCATION	DISCHARGE ALLOWED			DISCHARGE CONDITIONS	
	Draining	Cleaning	Backwash	pH	Chlorine Residual
Sanitary Sewer	YES	YES	YES	5.0 - 10.0	* ND
Surface Water Body	YES	NO	NO	6.0 - 9.0	* ND
Wetlands	NO	NO	NO	-	-
Ground Surface	YES	NO	NO	6.0 - 9.0	* ND
Subsurface Leaching	YES	NO	YES	6.0 - 9.0	* ND

\*ND: Non-Detectable as determined by a water test kit, or less than 0.1 mg/l

## DEFINITIONS:

SWIMMING POOL CLEANING WASTEWATERS are wastewaters and any other liquids generated by the acid cleaning of the sidewalls of swimming pools.

SWIMMING POOL DRAINING WASTEWATERS are wastewaters generated by the draining of water from swimming pools, and do not include Swimming Pool cleaning wastewaters.

SWIMMING POOL BACKWASH WASTEWATERS are wastewaters generated by backwashing a swimming pool filtering system.