

Town of Washington

Housatonic Valley Health District
10 Main Street – Town Hall
New Milford, CT 06776
Telephone: (860) 355-6035

5-11-2022

TO: [Brian Neff](#)

Date: ~~4-13-2022~~

FR: [Joe Kmetz](#)

Signed: 

RE: Review of Engineering Plan for Subsurface Sewage Disposal System located at:
87 Whittlesey Road Washington, Connecticut

Engineer: [Brian Neff](#)

Plan Date: ~~4-2-2022~~ Date Received: ~~4-11-2022~~

Reason for Submission

- Minimum percolation rate poorer than 30 minutes/inch
- High maximum ground water level
- New construction
- Shallow ledge rock
- Repair
- Other:


4-18-22


4-18-22

DESIGN SPECIFICATIONS:

Number of bedrooms 1

Septic tank 1,000 gallons

Fill system _____ inches

Design percolation rate 10-20 minutes/inch

Leaching system (1) Row of 12" Deep Concrete Galleries by 48 Feet long. Totaling 283.2 Square Feet of Effective Leaching Area.

Curtain drain _____

ACTION

- Approval.
- Approval Denied. Site unsuitable for sewage disposal
- Approval Denied. Insufficient information on plan. Revise as noted and resubmit.
- Approval Denied. Further site investigation required.

COMMENTS: